


STAIRWELL

ASHRAE DESIGN GUIDE 90.1 - 2010

RISER DIAGRAM



OPERATION:
 Switch ON/Dim
 On Level set for 100% dimming
 Off level set for 50% dimming
 Motion sensor set for Occupancy
 On at -100% / Un-Occupied at - 50%



5229 Edina Industrial Blvd.
 Minneapolis, MN 55439
 952.842.2564 | 800.922.8004
 ilc-usa.com

NUMBER	REVISIONS	DATE	SHEET INFORMATION
A	Code Riser CR0204	5-6-19	DATE: 5-6-19
1	-	-	SCALE: NONE
			DRAWN BY: JM

Project:

XX

STAIRWELL
ASHRAE 90.1
RISER

Title:

GO#

219xxxx

Sheet:

CR0204