


PRIVATE OFFICE WITH WINDOW

ASHRAE DESIGN GUIDE 90.1 - 2013

RISER DIAGRAM



OPERATION:
 Switch On/Off, dimming
 Motion sensor set for Vacancy
 Photocell limits max level in daylight zones
 Plug-load relay for 120V outlets
 operated by motion sensor on/off.
 Pre-Program F3



5229 Edina Industrial Blvd.
 Minneapolis, MN 55439
 952.829.1900 | ilc-usa.com

Project: XX			
NUMBER	REVISIONS	DATE	SHEET INFORMATION
E	Pre-Program	1-3-22	DATE: 1-3-22
			SCALE: NONE
			DRAWN BY: JM

PRIVAE OFFICE Title:
WITH WINDOW
ASHRAE 90.1
RISER

GO# 222xxxxx Sheet: CR0207