


CONFERENCE ROOM

ASHRAE DESIGN GUIDE 90.1 - 2010

RISER DIAGRAM



OPERATION:
 Switch ON/OFF
 On Level set for 50% dimming
 Motion sensor set for Vacancy
 Photocell limits max level in daylight zones



5229 Edina Industrial Blvd.
 Minneapolis, MN 55439
 952.842.2564 | 800.922.8004
 ilc-usa.com

Project: XX			
NUMBER	REVISIONS	DATE	SHEET INFORMATION
A	Code Riser CR0209	5-6-19	DATE: 5-6-19
1	-	-	SCALE: NONE
			DRAWN BY: JM

Title: CONFERENCE ROOM ASHRAE 90.1 RISER	
GO#	Sheet:
219xxxx	CR0209